



### **NOVA WS-80 MID**

## electronic single-phase energy meter multifunctional with the power monitor

with changes valid to: 7.6.2012 Features and specifications are subject to change.

### **USER MANUAL**

KRALGYSUP
Ing. Alena Kurillová & Ing. Leoš Rosol

Meinlinova 309/8 CZ-190 16 Praha 9 - Koloděje : 602 360 501(2)
: 281 970 988
: info@kralgroup.cz
http://www.kralgroup.cz

© KRALgroup

### **WARNING!**

Device installation and use must be carried out only by qualified staff.

Switch off the voltage before device installation.


Reprinting/transcript of this document or any kind of reproduction - even in part - is not permitted without the prior written permission of either the company TIP Thüringer Industrie Produkte GmbH or company KRAI group.

The content and the technical specification of this User Manual are subject to change without prior notice. They do not represent any contractual obligation.

KEEP THIS INSTRUCTION MANUAL - CONTAINS, I.A., EU-DECLARATION OF CONFORMITY

### **WIRING DIAGRAM**

### 1PHASE - 2 WIRES



### **AVAILABLE MODELS**

Model	Voltage	Frequency	MID certified
NOVA WS-80 MID	230 V	50 Hz	

In all device models, partial counters are resettable.


### **OVERVIEW**



- 1. Tariff input terminals
- 2. Terminals for the two S0 outputs
- 3. Backlight LCD display
- 4. Metrological LED
- 5. Multifunction key
- 6. Current, voltage and neutral terminals
- 7. Safety-sealing (DO NOT REMOVE)
- 8. Optical COM port




### SYMBOLS ON FRONT PANEL (EXAMPLE)




- A. Company logo
- B. Device name
- C. Type approval certification
- D. MID approval symbols
- E. Working temperature range
- F. Serial number
- G. Data Matrix
- H. Meter constant (metrological LED) RL
- I. Metrological LED symbol
- J. Protection class
- K. Wiring type (1phase, 2 wires)
- L. Nominal voltage/frequency
- M. Base current (max current) Imax
- N. Accuracy class

### **CABLE STRIPPING LENGTH**



### **DIMENSIONS (mm)**





- \*\* +420 602 360 502 \*\* +420 602 360 501
- \$\begin{align\*}
  +420 002 300 301 \\
  +420 281 970 988 \end{align\*}
- http://www.kralgroup.cz
- info@kralgroup.cz
- aklrpremagas@atlas.cz





### **SYMBOLS ON DISPLAY**

Display test can be carried out by pressing the key for 10 s.

SYMBOL	DESCRIPTION
<b>ERR</b>	Metrological parameters corrupted (Code: XX will be displayed in the main area). The counter cannot be used and it must be returned to the Manufacturer.
_1_2_	Active S0 output number
#	Delivered $(\rightarrow)$ , supplied $(\leftarrow)$ power or energy value
8888	Identify the Setup page (SETUP) or the Info page (INFO)
COM	Communication ON status
*	SETUP page
≑϶	Capacitive / inductive value
888888	Main area
BAL	Balance counter value. If a line is displayed over the symbol ( ), the displayed value is NEGATIVE.
PAR	Partial counter value. If flashing, the counter is stopped.
	1 or 2 tariff counter value
MkVAhMkWhMkvarh	Measuring unit area

### **KEY FUNCTIONS**

ноw то	WHERE	PRESS TIME
Scroll loops	Any page except for Setup	Twice quickly
Scroll pages in a loop	Any loops page	Instanta- neous
Access Setup pages	"Setup?" page	>3 s
Enable setup for a value/digit	Setup pages	Twice quickly
Change a value/digit	Setup pages	Instanta- neous
Confirm a value/digit	Setup pages	Twice quickly
Change item (Y, N, C)	"Save?" page	Instanta- neous
Confirm the displayed item (Y, N, C)	"Save?" page	>3 s
Display the functions available for the shown counter	Partial counter page	>3 s
Change function (Start, Stop, Reset)	Partial counter page	Instanta- neous
Confirm the displayed function (Start, Stop, Reset)	Partial counter page	>3 s
Display test	Any page except for Setup	>10 s

### **MEASUREMENTS**

	SYMBOL	MEASURE UNIT	DIS- PLAY	COM	S0 OUTPUT
INSTANTANEOUS	VALUES				
Voltage	V	V		•	
Current	I	А			
Power factor	PF			•	
Apparent power	S	kVA			
Active power	Р	kW			
Reactive power	Q	kvar			
Frequency	f	Hz		•	
Power direction	IMP/EXP (Supply/Delivery)		•	•	

	SYMBOL	MEASURE UNIT	DIS- PLAY	COM	S0 OUTPUT
RECORDED DATA					
Total active energy	L	kWh			
Total reactive energy ind. and cap.	L	kvarh	-	•	-
Total apparent energy ind. and cap.	L	kVAr	-	-	-
T1/T2 tariff energy	L	kWh, kvarh, kVAh			
Resettable partial energy counters	L	kWh, kvarh, kVAh	-	•	
Energy balance	L	kWh, kvarh, kVAh			
OTHER INFORMATION	SYMBOL	VALUE / STATUS	DIS- PLAY	COM	
Present tariff	Т	1/2		•	
Undervoltage/overvoltage	VOL, VUL	ON/OFF		•	
Undercurrent / overcurrent	IOL, IUL	ON/OFF		•	
Underfrequency/overfrequency	fOL, fUL	ON/OFF		•	
Partial counters	PAR	START/STOP	•	•	
Active communication	COM	ON/OFF	•		
Active S0 pulse	S0-1, S0-2	ON/OFF	•		
		0.4.00			
Error condition	ERR	01/02		•	


All the system counters  $(\Sigma)$  programmable for S0 outputs are shown in "SO OUTPUT" column. It is not allowed to set the same counter for both outputs.

### **BALANCE COUNTER VALUES CALCULATION**

BALANCE COUNTER	FORMULA
kWh	$[\rightarrow$ kWh T1] – $[\leftarrow$ kWh T1] + $[\rightarrow$ kWh T2] – $[\leftarrow$ kWh T2]
kVAh ind	$[\rightarrow$ kVAh ind T1] – $[\leftarrow$ kVAh ind T1] + $[\rightarrow$ kVAh ind T2] – $[\leftarrow$ kVAh ind T2]
kVAh cap	$[\rightarrow$ kVAh cap T1] – $[\leftarrow$ kVAh cap T1] + $[\rightarrow$ kVAh cap T2] – $[\leftarrow$ kVAh cap T2]
kvarh ind	$[\rightarrow$ kvarh ind T1] – $[\leftarrow$ kvarh ind T1] + $[\rightarrow$ kvarh ind T2] – $[\leftarrow$ kvarh ind T2]
kvarh cap	[→kvarh cap T1] – [←kvarh cap T1] + [→kvarh cap T2] – [←kvarh cap T2]

### **PAGE STRUCTURE**

Device pages are grouped in 5 loops.







<del>4</del> +420 281 970 988

http://www.kralgroup.cz

info@kralgroup.cz

<u>aklrpremagas@atlas.cz</u>





### HOW TO START/STOP/RESET PARTIAL COUNTERS

Feature available only on partial counter pages.


### HOW TO START DISPLAYED PARTIAL COUNTER




## HOW TO STOP DISPLAYED PARTIAL COUNTER PREVIOUSLY STARTED



### HOW TO RESET DISPLAYED PARTIAL COUNTER




### **SETUP PAGES**







# →<sup>SEE</sup> \*\*



## [0]],





kVAh

## MBUS SECONDARY ADDRESS (0...99999999)

## Available only in case of combined MBUS module

The value is displayed on 2 pages:

- page 1 (→): digit from 7 to 1
   page 2 (←): digit from 8 to 2
- 1. Press the key twice quickly, the digit 8 of the secondary address will start to flash.
- 2. Press the key once to change the value.
- Confirm by pressing the key twice quickly.
- 4. Repeat points 2 and 3 for the other digits.

### MODBUS MODE (RTU=8N1, ASCII=7E2) Available only in case of combined RS485 module

- 1. Press the key twice quickly, the mode will start to flash.
- Press the key once to change the mode.
- 3. Confirm by pressing the key twice quickly

# COMMUNICATION SPEED Page and range available according to the combined communication module

- 1. Press the key twice quickly, the value will start to flash.
- 2. Press the key once to change the value.
- 3. Confirm by pressing the key twice quickly.

## REGISTER ASSIGNED TO S0 OUTPUT (1-2)

- Press the key twice quickly, the items which identify the register (e.g. →, kWh) will start to flash.
- 2. Press the key once to change the register to be assigned to the output.
- 3. Confirm by pressing the key twice quickly.





\*\* +420 602 360 502 \*\* +420 602 360 501

+420 602 360 501 +420 281 970 988 http://www.kralgroup.czinfo@kralgroup.cz

□ Inlo@kraigroup.cz
 □ aklrpremagas@atlas.cz

001JP.03







### **PARTIAL COUNTERS RESET**

- Press the key twice quickly, a new page for confirmation will be displayed.
- 2. Press the key once to change the flashing value, Y to confirm the reset, N to cancel.
- 3. Confirm by pressing the key at least

### **SETUP PAGES**



>3s

### ON ANY SETUP PAGE

- **EXIT FROM SETUP**  Press the key once to change the fla-shing value, Y to exit and save the settings, N to exit without saving, C to continue scrolling setup pages.
- 2. Confirm by pressing the key at least

### **INFO PAGES**

Up to 3 INFO pages can be displayed to show details about:

- 1. counter firmware version
- 2. checksum
- 3. combined communication module in use

The third page, which shows communication module in use, can change according to the module combined with the counter (see table). If the counter has no combined module this page will not be displayed.

COMBINED COMMUNICATION MODULE	DETAIL DISPLAYED ON THE INFO PAGE
RS485 MODBUS	Modbus
M-BUS	Mbus
LAN GATEWAY	Lan
EIB/KNX i.V	(no info - in preparation)









info@kralgroup.cz

<u>aklrpremagas@atlas.cz</u>





### **TECHNICAL FEATURES**

Data in compliance with standards	EN50470-1, EN 50470-3, EN 62053-23, EN 62053-31
GENERAL	
Housing in compliance with standard	DIN 43880
Terminals in compliance with standard	EN 60999
AUXILIARY POWER SUPPLY	
Power supplied from the voltage	-
circuit	
Nominal measurement voltage	±20%
Consumption	7,5 VA max.
Nominal frequency	50 Hz
VOLTAGE/FREQUENCY AND WIRIN	
MODEL WIRING	V f
NOVA WS-80 MID 1 phase 2 wire	es 230 V 50 Hz
CURRENT (A)	
Maximum current Imax	80 A
Basic current Iref (Ib)	5 A
Ratio current Itr	500 mA
Minimum current Imin	250 mA
Starting current lst	20 mA
ACCURACY	24 1111 7
Active energy class B according to	EN 50470-1-3
Reactive energy class A according to	EN 62053-23
2 S0 OUTPUTS	LIV 02033-23
Passive optoisolated	TN 62052 24) 250 V. a. a. 400 A
Maximum values (in compliance with I	
Pulse length	50 ±2ms ON time min. 30 ±2ms OFF time
TARIFF INPUT	00 120 011 10
Active optoisolated	
Minmax. voltage	276 VAC-DC
METROLOGICAL LED	210 170-50
Meter constant RL	1000 lmp /kWb
	1000 Imp./kWh
WIRE DIAMETER FOR TERMINALS	4.5.05. 2
Measuring terminals (A & V)	1,535 mm²
S0 output / tariff terminals	0,142,5 mm²
SAFETY ACCORDING TO EN 50470	-1 STANDARD
Indoor installation	-
Pollution degree	2
Protective class (EN 50470)	II
Pulse voltage test	1,2/50µs 6kV
AC voltage test (EN 50470-3, 7.2)	4 kV
Housing material flame resistance	UL 94 class V0
ENVIRONMENTAL CONDITIONS	
Mechanical environmental	M1
Electromagnetic environmental	E2
Operating temperature	-25°C +55°C
Storage temperature	-25°C +75°C
Storage temperature	
Relative humidity (without condensation	on) <b>max. 80</b> %
Relative humidity (without condensation Sinusoidal vibration amplitude	on) max. 80% 50 Hz ±0,075 mm
Relative humidity (without condensation Sinusoidal vibration amplitude Protection degree - frontal part (granted only in	on) max. 80% 50 Hz ±0,075 mm
Relative humidity (without condensation Sinusoidal vibration amplitude	on) max. 80% 50 Hz ±0,075 mm

### METROLOGICAL LED AND PULSES ON S0 OUTPUT

METROLOGICAL LED PULSES	S0 PULSES RA	
1000 lmp./kWh	500 lmp./kWh & lmp./kvarh & lmp./kVAh	

### **WASTE DISPOSAL**

ATTENTION - Dispose of ecologically! Does not belong to the mixed waste!

This product may not be, at the end of its useful life, disposed of with normal household waste but must be returned to a collection point for recycling of electronic equipment. Please check with your dealer or local authorities for disposal of the competent authority.



### EXAMPLES OF READINGS AND CALCULATED CONSUMPTION:

Date of	Register-/-s status			Calculated	
reading		Initial	Final	consumption	
	T1 kWh:				
	T2 kWh:				
	T1 kVArh:				
	T2 kVArh:				
	T1 kWh:				
	T2 kWh:				
	T1 kVArh:				
	T2 kVArh:				
	T1 kWh:				
	T2 kWh:				
	T1 kVArh:				
	T2 kVArh:				
	T1 kWh:				
	T2 kWh:				
	T1 kVArh:				
	T2 kVArh:				
	T1 kWh:				
	T2 kWh:				
	T1 kVArh:				
	T2 kVArh:				
	T1 kWh:				
	T2 kWh:				
	T1 kVArh:				
	T2 kVArh:				
	T1 kWh:				
	T2 kWh:				
	T1 kVArh:				
	T2 kVArh:				
	T1 kWh:				
	T2 kWh:				
	T1 kVArh:				
	T2 kVArh:				

- 1) Register status = overwritten value according to counter status
- 2) Calculated consumption = difference between final and initial state of the counter







http://www.kralgroup.cz



<u>aklrpremagas@atlas.cz</u>







### **EU-DECLARATION OF CONFORMITY:**

SINGLE-PHASE, STATIC ENERGY-HOUR Product name:

**METER OF ACTIVE AND REACTIVE ENERGY IN BOTH DIRECTIONS OF** 

**ENERGY FLOW** 

**NOVA WS-80 MID** Type of designation:

EC-Type test certificate: 153/MID

Number and address of notified person: (Module B+D) 0051

IMQ SpA Via Quintiliano 43 I-20138 MILANO

Metrology marking: CE-M13-0051

The energy-hour meters of type NOVA WS-80 MID meet the requirements of EN50470-1, EN 50470-3, EN 62053-23, EN 62053-31 of both current directions of class B for active energy and of class A for reactive energy for direct connection into the three-phase electricity network.

Potential-free-pulse-transmitter complies with DIN EN 62053-31 standard for installation of broadcasting impulses for Class A and B for the transmitter o type

The meter conforms to MID requirements for billing and metering as two-tariffs energy meter with regards to the terms and to the way of its connection to the single-phase electricity network.

The external dimensions of the meter corresponds to the built-in devices of the 2-modules (2-TE) size according to DIN 43880 standard.

Installation of the energy meters is designed for mounting on a standard DIN-rail 35 mm wide according to DIN EN 50022 standard.

The electric protection class of the energy meters corresponds to IP20 (IP51) according to DIN EN 60529 standard.

Prague, 22.10.2013



### Your partner for measuring the energy

DIN RAIL MOUNTED kWh METERS RE/CONDITIONED kWh METER PRE/PAZMENT kWh METERS CREDIT CARDS kWh METERS GSM OPERATED kWh METERS SPECIAL kWh METERS OTHERS FOR THE MEASUREMENT OF EL. ENERGY

**CURRENT TRANSFORMERS** 

MEASURING POWER IN HARBORS AND ANCHORAGE SHIP (MARINAS)

MEASURING POWER IN THE CAMP, IN TRADE FAIR, EXHIBITION, BUSINESS, COMMERCIAL AND ADMINISTRATIVE CENTERS

**ENERGY MANAGEMENT SYSTEMS** (M-Bus, PLC, GSM, RS-485, EIB, INSTA-BUS)

Our advice is for You with pleasure

© KRALgroup

